



NOTES:

1. BUILDING J IS 'FULLY SPRINKLERED' WHICH INCLUDES OPEN PARKING BELOW.
2. 'IMAGINARY LINE' ONLY REQUIRED TO DETERMINE RATINGS OF WALLS - NO WALL IS REQUIRED FOR OPEN PARKING.