



01	DUCT-TYPE SMOKE DETECTOR WHICH WOULD SHUT OFF THE GAS AND ELECTRICITY TO THE FURNACE UPON ACTIVATION.
02	REQUIRED CLOSURE MINIMUM 20min RATED DOOR w/ SELF CLOSING DEVICE, PROVIDE SMOKE-TIGHT SEAL.
03	SUITE MAIN ENTRANCE DOOR WITH 50% GLAZING (REFER TO A11 FOR FURTHER DETAILS)
04	SUITE MAIN ENTRANCE DOOR (REFER TO A11 FOR FURTHER DETAILS)
05	INTERIOR DOOR BETWEEN SUITES (REFER TO A11 FOR FURTHER DETAILS)
06	3 OR 2 (DEPEND UPON THE FLOOR JOIST ORIENTATION) , 2x10 SPF MIN. # 2 HEADERS (REFER TO A10 FOR FURTHER DETAILS)

LEGEND:		LEGEND:	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
	INTERCONNECTED SMOKE ALARM WITH VISUAL SIGNAL.		RETURN - AIR GRILLE, PROVIDED IN ALL FIRE COMPARTMENTS, SHALL NOT BE INSTALLED WITHIN FIRE SEPARATIONS.
	CARBON MONOXIDE DETECTOR		TYPICAL INTERIOR WALL FOR FURTHER DETAILS SEE PAGE A10
	WARM AIR SUPPLY OUTLET FITTED WITH RADIATION DAMPER (MIN 1/4" RATED) FOR WOODEN JOIST FIRE RATED CEILING ASSEMBLIES, FULFILLING THE REQUIREMENTS OF OBC 9.10.5.1(4), 9.13.1.3.13 AND 9.10.1.3.14 AND NFPA 90A AND NFPA 101 COMPLIANCE ALTERNATIVES AS PER TABLE 11.5.1.1.C C.110 AND C.200		W50 OR W50b (FROM SB-03), FOR FURTHER DETAILS SEE PAGE A10
			CEILING HEIGHT TAG.
			EXHAUST FAN VENTED DIRECTLY TO EXTERIOR MIN. 50 CFM

ALL DRAWINGS ARE THE PROPERTY OF THE DESIGNER AND THEY ARE NOT TO BE REPRODUCED IN WHOLE OR IN PART WITHOUT WRITTEN CONSENT FROM THE DESIGNER.

CONTRACTOR TO CHECK AND VERIFY ALL DIMENSIONS BEFORE COMMENCING WORK AND TO REPORT ANY DISCREPANCIES TO THE DESIGNER. DRAWINGS NOT TO BE SCALED AND REPRODUCED.

ALL CONSTRUCTION TO BE ACCORDING TO BEST COMMON PRACTICE AND CONFORM TO THE ONTARIO BUILDING CODE.

1	PERMIT DRAWING	16/01/2026
No.	ISSUED	DATE

STRUCTURE / MEP ENGINEER:

DESIGNER

CLIENT

PROJECT

DRAWING

PLAN

PROJECT NO
57

DRAWN
BAK

PLOTTED DATE
16/01/2026

SCALE
AS NOTED

CHECKED
ALK

DWG. NO. **A3**